

## **SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9 Client Name: CalTrans **Run date** 21-Nov-14 **Time** 5:33 PM

04-0120F4

04-SF-80-13.2/13.9

Self-Anchored

**Suspension Bridge** 

## Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 064 Const Calendar Day: 1000 Date: 04-Jun-2012 Monday Inspector Name: Awal, Mohammad Title: Transportation Engineer

Inspection Type: Intermittent

**Shift Hours:** 07:00 am 05:30 pm **Break**: 00:30 **Over Time**: 02:00

Federal ID: Location:

Reviewer: Woods, Mark Approved Date: 28-Sep-12 Status: Approved

Weather

 Temperature
 7 AM
 50 - 60
 12 PM
 50 - 60
 4PM
 50 - 60

 Precipitation
 Condition
 Sunny

Working Day **V** If no, explain:

Diary:

**Tower Activities** 

Welding:

13 m Diaphragm: (J. Lizardo)

Undercut repairs of North & South stiffener plate of outer east diaphragm.

Eletro-Slag Weld (ESW) (QA: W. Clifford)

QA UT verification on North shear plate ESW weld designated "N" and "W" in progress.

QC UT verification on weld "V" and "T" in progress.

Details of welding operation are available in QA reports.

04-0120F4	Bid Item: 053	3 T-L01-SPD.053	Tower Lift 01 Shear Plates and Diaphrams	
AMERICAN BRIDGE/FLUOR, A JV				
Labor				
Trade	Class	Name	RT Hrs OT Hrs DT Hrs Total Remarks	Dispute
Contractor:	AMERICAN BRIDGE	/FLUOR, A JV		
Welder	APP	Reggie Humphry	8.00 2.00 0.00 10.00	
Welder	JNM	Luo HUA	8.00 2.00 0.00 10.00	
Welder	JNM	HAN YU	8.00 2.00 0.00 10.00	
Ironworker	JNM	XIAO JIAN WAN	8.00 2.00 0.00 10.00	
Ironworker	FOR	JAMES ZHEN	8.00 2.00 0.00 10.00	
Ironworker	APP	MAN MA	8.00 2.00 0.00 10.00	
Ironworker	JNM	WAI KIT LAI	8.00 2.00 0.00 10.00	
Ironworker	JNM	JIN PEI WANG	8.00 2.00 0.00 10.00	



Page 1 of 1